



Jim Doyle, Governor Mary P. Burke, Secretary

October 18, 2006

N.E.W. LUBE & REPAIR RANDY IHLENFELDT N2041 HWY 42 KEWAUNEE WI 54216

Re: Description: SEWAGE TANKS, STEEL Manufacturer: N.E.W. LUBE & REPAIR

Product Name: WASTE WATER HOLDING TANK Model Number(s): N.E.W. 001 (2780 GALLONS 3/4 FULL)

Product File No: 20060464

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2011.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be labeled with the manufacturer's name and model number in a location that is accessible.

A copy of the approved plans and/or specifications is enclosed.

A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wi.gov

SBD-10564-E (N.10/97) File Ref: 06046401.DOC